



### CERTIFICATE OF ANALYSIS

**Customer :** Garden State Environmental  
555 South Broad Street, Suite K  
Glen Rock, NJ

**Project ID :** North Brunswick BOE #6526

**PAS Project ID :** P17-0450

**Matrix :** Drinking Water  
**Report Date :** 02/22/17

| PAS Sample ID | Client ID      | Analysis | Results | Units | DF | PQL  | MDL   | MCL    | Method    | Date Sampled   | Date Analyzed |
|---------------|----------------|----------|---------|-------|----|------|-------|--------|-----------|----------------|---------------|
| P17-0450-01   | S# 98          | Lead     | 2.24    | ug/L  | 1  | 2.00 | 0.462 | 15.0 * | SM 3113 B | 12/30/16 08:12 | 2/6/17 15:53  |
| P17-0450-02   | S# 98B         | Lead     | 0.594 J | ug/L  | 1  | 2.00 | 0.462 | 15.0 * | SM 3113 B | 12/30/16 09:59 | 2/6/17 16:05  |
| P17-0450-03   | S# 100B        | Lead     | 0.594 J | ug/L  | 1  | 2.00 | 0.462 | 15.0 * | SM 3113 B | 12/30/16 10:00 | 2/6/17 16:10  |
| P17-0450-04   | B# 25B         | Lead     | 10.8    | ug/L  | 1  | 2.00 | 0.462 | 15.0 * | SM 3113 B | 12/30/16 08:29 | 2/6/17 16:10  |
| P17-0450-05   | NBJA-12-30-FBB | Lead     | ND      | ug/L  | 1  | 2.00 | 0.462 | 15.0 * | SM 3113 B | 12/30/16 11:05 | 2/6/17 16:14  |

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

B = Compound found in blank and samples

E = Concentration exceeds calibration range

J = Estimated result

\* Federal Action Level

All samples are analyzed in accordance with  
New Jersey Department of Environmental  
Protection Protocol

Mark D. Feitelson, Lab. Director