



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : North Brunswick BOE- Maple Meade #6526
PAS Project ID : P17-1086

Matrix : Drinking Water
Report Date : 3/13/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-1086-01	S#3 A	Lead	5.00	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 11:35	3/9/17 11:34
P17-1086-02	S#4 A	Lead	10.5	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 11:38	3/9/17 11:39
P17-1086-03	S#5 A	Lead	11.5	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 11:40	3/9/17 11:43
P17-1086-04	B#6 A	Lead	6.25	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 11:42	3/9/17 11:48
P17-1086-05	S#7 A	Lead	0.984 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 11:43	3/9/17 11:52
P17-1086-06	S#8 A	Lead	0.984 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 11:46	3/9/17 11:56
P17-1086-07	S#9 A	Lead	0.734 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 11:46	3/9/17 12:21
P17-1086-08	S#10 A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 11:48	3/9/17 12:34
P17-1086-09	B#11 A	Lead	5.25	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 11:51	3/9/17 12:38
P17-1086-10	IC#12 A	Lead	1.74 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 11:57	3/9/17 12:42
P17-1086-11	S#13 A	Lead	3.24	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 11:55	3/9/17 12:46
P17-1086-12	CM#14 A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 11:54	3/9/17 12:50
P17-1086-13	S#15 A	Lead	3.74	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 12:03	3/9/17 13:03
P17-1086-14	S#16 A	Lead	3.99	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 12:04	3/9/17 13:07
P17-1086-15	S#17 A	Lead	0.734 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 12:08	3/9/17 13:11
P17-1086-16	S#19 A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 12:10	3/9/17 13:16
P17-1086-17	S#20 A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 12:12	3/9/17 13:20
P17-1086-18	S#21A	Lead	7.50	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 12:13	3/9/17 13:24
P17-1086-19	S#22 A	Lead	6.75	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 12:15	3/9/17 13:29
P17-1086-20	S#23 A	Lead	14.0	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 12:16	3/9/17 13:33
P17-1086-21	NBMM-3-5-FBA	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/5/17 12:20	3/9/17 13:57

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- B = Compound found in blank and samples
- E = Concentration exceeds calibration range
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director