



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : North Brunswick BOE - High School - #6526
PAS Project ID : P17-1192

Matrix : Drinking Water
Report Date : 3/23/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-1192-01	S#2A	Lead	1.20	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:10	3/20/17 13:53
P17-1192-02	S#3A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:12	3/20/17 14:06
P17-1192-03	S#4A	Lead	2.84	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:13	3/20/17 14:10
P17-1192-04	B#7A	Lead	0.995	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:16	3/20/17 14:14
P17-1192-05	B#8A	Lead	0.585	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:17	3/20/17 14:18
P17-1192-06	WC#17A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:21	3/20/17 14:23
P17-1192-07	WC#18A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:21	3/20/17 14:27
P17-1192-08	S#20A	Lead	3.46	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:23	3/20/17 14:31
P17-1192-09	S#21A	Lead	0.790	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:24	3/20/17 14:36
P17-1192-10	S#24A	Lead	2.43	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:27	3/20/17 15:52
P17-1192-11	IC#26A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:29	3/20/17 15:56
P17-1192-12	WC#28A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:31	3/20/17 16:00
P17-1192-13	WC#29A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:32	3/20/17 16:21
P17-1192-14	S#37A	Lead	0.790	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:34	3/20/17 16:25
P17-1192-15	WC#40A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:37	3/20/17 16:29
P17-1192-16	B#51A	Lead	4.28	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:38	3/20/17 16:33
P17-1192-17	S#54A	Lead	18.4	ug/L	2	4.00	0.924	15.0 *	SM 3113 B	3/12/17 07:40	3/20/17 17:13
P17-1192-18	WC#55A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:43	3/20/17 16:42
P17-1192-19	S#56A	Lead	1.41	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:43	3/20/17 16:46
P17-1192-20	S#57A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:45	3/20/17 16:51
P17-1192-21	WC#58A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:47	3/20/17 16:55
P17-1192-22	S#59A	Lead	2.95	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:48	3/21/17 11:38
P17-1192-23	S#67A	Lead	1.60	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:03	3/21/17 11:46
P17-1192-24	WC#68A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:51	3/21/17 11:59
P17-1192-25	WC#69A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:52	3/21/17 12:12
P17-1192-26	WC#80A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:53	3/21/17 12:16
P17-1192-27	B#76A	Lead	4.50	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:55	3/21/17 12:20
P17-1192-28	S#77A	Lead	0.834	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:56	3/21/17 12:24
P17-1192-29	S#78A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:57	3/21/17 12:28
P17-1192-30	S#79A	Lead	1.22	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:02	3/21/17 12:33
P17-1192-31	B#82A	Lead	0.641	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:06	3/21/17 12:37
P17-1192-32	WC#83A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:08	3/21/17 12:41
P17-1192-33	S#92A	Lead	1.03	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:10	3/21/17 12:45
P17-1192-34	WC#88A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:12	3/21/17 12:58
P17-1192-35	S#89A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:14	3/21/17 13:03
P17-1192-36	S#91A	Lead	1.22	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:12	3/21/17 13:07
P17-1192-37	S#95A	Lead	8.74	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:16	3/21/17 13:12
P17-1192-38	WC#108A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:20	3/21/17 13:16
P17-1192-39	WC#107A	Lead	1.22	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:21	3/21/17 13:20
P17-1192-40	S#105A	Lead	8.35	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:23	3/21/17 13:25
P17-1192-41	S#100A	Lead	22.9	ug/L	2	4.00	0.924	15.0 *	SM 3113 B	3/12/17 08:25	3/21/17 14:51
P17-1192-42	WC#103A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:28	3/21/17 13:33
P17-1192-43	WC#104A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:28	3/21/17 13:51
P17-1192-44	S#106A	Lead	4.30	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:30	3/21/17 14:03
P17-1192-45	WC#109A	Lead	0.641	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:32	3/21/17 14:08
P17-1192-46	S#114A	Lead	1.22	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:34	3/21/17 14:12
P17-1192-47	S#112A	Lead	0.834	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:36	3/21/17 14:16

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
B = Compound found in blank and samples
E = Concentration exceeds calibration range
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : North Brunswick BOE - High School - #6526

PAS Project ID : P17-1192

Matrix : Drinking Water

Report Date : 3/23/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-1192-48	SH113A	Lead	1.22	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:36	3/21/17 14:20
P17-1192-49	SH111A	Lead	2.57	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:38	3/21/17 14:55
P17-1192-50	SH110A	Lead	0.641	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:40	3/21/17 14:59
P17-1192-51	SH115A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:43	3/21/17 15:03
P17-1192-52	SH120A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:46	3/21/17 15:08
P17-1192-53	SH121A	Lead	4.50	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:48	3/21/17 15:12
P17-1192-54	WC#126A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:51	3/21/17 15:16
P17-1192-55	WC#127A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:52	3/21/17 15:20
P17-1192-56	WC#128A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:53	3/21/17 15:24
P17-1192-57	WC#129A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:53	3/21/17 15:37
P17-1192-58	SH130A	Lead	0.641	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:58	3/21/17 15:41
P17-1192-59	SH133A	Lead	0.834	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:02	3/21/17 15:46
P17-1192-60	WC#134A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:06	3/21/17 15:50
P17-1192-61	SH135A	Lead	2.18	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:08	3/21/17 15:54
P17-1192-62	SH137A	Lead	1.47	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:08	3/21/17 11:47
P17-1192-63	SH136A	Lead	1.21	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:10	3/21/17 11:56
P17-1192-64	SH138A	Lead	0.947	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:12	3/21/17 12:08
P17-1192-65	SH139A	Lead	0.947	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:13	3/21/17 12:21
P17-1192-66	WC#148A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:17	3/21/17 12:25
P17-1192-67	WC#149A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:17	3/21/17 12:30
P17-1192-68	WC#150A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:23	3/21/17 12:34
P17-1192-69	SH163A	Lead	0.684	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:20	3/21/17 12:38
P17-1192-70	SH162A	Lead	33.6	ug/L	3	6.00	1.39	15.0 *	SM 3113 B	3/12/17 09:21	3/21/17 14:07
P17-1192-71	SH164A	Lead	0.947	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:23	3/21/17 12:47
P17-1192-72	WC#153A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:29	3/21/17 12:51
P17-1192-73	WC#154A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:29	3/21/17 12:55
P17-1192-74	SH168A	Lead	5.42	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:31	3/21/17 13:08
P17-1192-75	SH167A	Lead	3.84	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:32	3/21/17 13:13
P17-1192-76	SH155A	Lead	0.684	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:35	3/21/17 13:17
P17-1192-77	WC#151A	Lead	0.684	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:38	3/21/17 13:21
P17-1192-78	WC#152A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:38	3/21/17 13:26
P17-1192-79	WC#156A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:40	3/21/17 13:30
P17-1192-80	WC#157A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:40	3/21/17 13:35
P17-1192-81	SH166A	Lead	1.21	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:41	3/21/17 13:39
P17-1192-82	SH158A	Lead	2.26	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:44	3/21/17 13:43
P17-1192-83	SH171A	Lead	1.74	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:46	3/21/17 14:12
P17-1192-84	WC#159A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:48	3/21/17 14:24
P17-1192-85	WC#160A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:49	3/21/17 14:28
P17-1192-86	SH190A	Lead	1.21	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:55	3/21/17 14:33
P17-1192-87	SH187A	Lead	0.947	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:57	3/21/17 14:37
P17-1192-88	SH173A	Lead	3.32	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:00	3/21/17 14:50
P17-1192-89	SH174A	Lead	0.947	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:02	3/21/17 14:54
P17-1192-90	SH172A	Lead	2.00	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:04	3/21/17 14:58
P17-1192-91	SH175A	Lead	4.89	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:06	3/21/17 15:02
P17-1192-92	SH176A	Lead	2.00	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:07	3/21/17 15:06
P17-1192-93	SH180A	Lead	3.58	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:09	3/21/17 15:11
P17-1192-94	O#178A	Lead	1.21	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:11	3/21/17 15:15

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
B = Compound found in blank and samples
E = Concentration exceeds calibration range
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : North Brunswick BOE - High School - #6526
PAS Project ID : P17-1192

Matrix : Drinking Water
Report Date : 3/23/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-1192-95	O#179A	Lead	5.95	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:16	3/21/17 15:19
P17-1192-96	S#177A	Lead	2.53	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:18	3/21/17 15:24
P17-1192-97	S#182A	Lead	3.32	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:19	3/21/17 15:45
P17-1192-98	S#183A	Lead	3.32	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:20	3/21/17 15:49
P17-1192-99	S#184A	Lead	1.21	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:21	3/21/17 15:53
P17-1192-100	B#304A	Lead	3.84	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:30	3/21/17 15:57
P17-1192-101	IC#312A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:32	3/21/17 16:01
P17-1192-102	B#272A	Lead	1.03	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:34	3/21/17 15:58
P17-1192-103	IC#278A	Lead	1.41	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:37	3/21/17 16:28
P17-1192-104	S#277A	Lead	33.4	ug/L	4	8.00	1.85	15.0 *	SM 3113 B	3/12/17 10:38	3/21/17 17:14
P17-1192-105	S#218A	Lead	3.73	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:41	3/21/17 16:42
P17-1192-106	S#192A	Lead	1.60	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:44	3/21/17 16:46
P17-1192-107	S#193A	Lead	1.41	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:47	3/21/17 16:50
P17-1192-108	S#202A	Lead	0.834	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:50	3/21/17 16:55
P17-1192-109	S#201A	Lead	0.834	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:49	3/21/17 17:18
P17-1192-110	B#194A	Lead	1.03	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:53	3/21/17 17:22
P17-1192-111	B#207A	Lead	1.03	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:56	3/21/17 17:27
P17-1192-112	S#208A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:58	3/21/17 17:31
P17-1192-113	S#214A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 11:00	3/21/17 17:35
P17-1192-114	S#224A	Lead	13.9	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 11:03	3/21/17 17:39
P17-1192-115	S#225A	Lead	1.99	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 11:05	3/21/17 17:48
P17-1192-116	S#251A	Lead	11.5	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 11:07	3/21/17 16:06
P17-1192-117	WC#328A	Lead	0.684	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 11:11	3/21/17 16:14
P17-1192-118	WC#329A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 11:11	3/21/17 16:35
P17-1192-119	WC#321A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 11:13	3/21/17 16:39
P17-1192-120	WC#322A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 11:14	3/21/17 16:44
P17-1192-121	WC#320A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 11:16	3/21/17 16:48
P17-1192-122	WC#323A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 11:19	3/21/17 16:52
P17-1192-123	WC#324A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 11:19	3/21/17 16:57
P17-1192-124	NBHS-3-12-FBA	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 12:45	3/21/17 17:01
P17-1192-125	IC#181A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 10:23	3/21/17 17:05
P17-1192-126	S#170A	Lead	2.00	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 09:50	3/21/17 17:18
P17-1192-127	WC#38A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 07:34	3/21/17 17:23
P17-1192-128	S#131A	Lead	0.947	J ug/L	1	2.00	0.462	15.0 *	SM 3113 B	3/12/17 08:55	3/21/17 17:27

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- B = Compound found in blank and samples
- E = Concentration exceeds calibration range
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : North Brunswick BOE - Linwood #6526
PAS Project ID : P17-1189

Matrix : Drinking Water
Report Date : 3/22/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-1189-01	S#50B	Lead	0.790 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/13/17 01:38	3/20/17 11:11
P17-1189-02	S#146B	Lead	6.33	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/13/17 02:01	3/20/17 11:19
P17-1189-03	S#82B	Lead	2.64	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/13/17 03:24	3/20/17 11:32
P17-1189-04	NBLMS-2-13-FBB	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/13/17 12:55	3/20/17 11:44

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- B = Compound found in blank and samples
- E = Concentration exceeds calibration range
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director