



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : North Brunswick BOE #6526
PAS Project ID : P16-7048

Matrix : Drinking Water
Report Date : 01/09/17

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P16-7048-01	S#4A	Lead	5.18	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 01:30	1/4/17 11:41
P16-7048-02	S#105A	Lead	17.4	ug/L	2	4.00	0.924	15.0 *	SM 3113 B	12/22/16 01:30	1/4/17 12:26
P16-7048-03	O#6A	Lead	7.71	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 01:36	1/4/17 12:02
P16-7048-04	O#7A	Lead	13.9	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 01:40	1/4/17 12:30
P16-7048-05	WC#9A	Lead	0.122 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 01:45	1/4/17 12:34
P16-7048-06	S#15A	Lead	6.16	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 01:47	1/4/17 12:38
P16-7048-07	S#16A	Lead	7.32	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 01:50	1/4/17 12:59
P16-7048-08	B#17A	Lead	13.6	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 01:53	1/4/17 13:03
P16-7048-09	WC#18A	Lead	0.900 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 01:52	1/4/17 13:08
P16-7048-10	B#19A	Lead	3.24	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 01:56	1/4/17 13:12
P16-7048-11	S#20A	Lead	4.60	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 01:59	1/4/17 13:16
P16-7048-12	WC#21A	Lead	0.900 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:02	1/4/17 13:25
P16-7048-13	S#23A	Lead	1.87 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:06	1/4/17 13:29
P16-7048-14	WC#27A	Lead	0.122 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:04	1/4/17 13:33
P16-7048-15	B#29A	Lead	0.122 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:11	1/4/17 13:38
P16-7048-16	B#31A	Lead	0.511 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:14	1/4/17 13:51
P16-7048-17	B#33A	Lead	0.122 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:17	1/4/17 13:55
P16-7048-18	B#35A	Lead	0.122 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:19	1/4/17 14:00
P16-7048-19	B#37A	Lead	0.706 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:26	1/4/17 14:04
P16-7048-20	B#39A	Lead	0.706 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:23	1/4/17 14:08
P16-7048-21	B#42A	Lead	9.08	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:29	1/4/17 14:13
P16-7048-22	B#44A	Lead	3.63	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:31	1/4/17 14:21
P16-7048-23	S#48A	Lead	10.6	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:35	1/4/17 15:03
P16-7048-24	B#50A	Lead	3.24	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:38	1/4/17 15:07
P16-7048-25	B#52A	Lead	11.6	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:40	1/4/17 15:11
P16-7048-26	B#54A	Lead	2.07	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:44	1/4/17 15:15
P16-7048-27	B#55A	Lead	3.43	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:46	1/4/17 15:20
P16-7048-28	B#56A	Lead	0.316 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:48	1/4/17 15:51
P16-7048-29	B#57A	Lead	0.316 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:54	1/4/17 15:55
P16-7048-30	B#58A	Lead	0.316 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 02:57	1/4/17 15:59
P16-7048-31	B#59A	Lead	0.122 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:00	1/4/17 16:04
P16-7048-32	WC#65LA	Lead	0.316 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:06	1/4/17 16:08
P16-7048-33	WC#65RA	Lead	0.122 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:07	1/4/17 16:12
P16-7048-34	S#67A	Lead	0.511 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:10	1/4/17 16:17
P16-7048-35	B#69A	Lead	0.511 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:13	1/4/17 16:21
P16-7048-36	B#70A	Lead	0.122 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:16	1/4/17 16:44
P16-7048-37	B#71A	Lead	0.316 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:18	1/4/17 16:48
P16-7048-38	B#73A	Lead	0.122 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:21	1/4/17 16:52
P16-7048-39	B#74A	Lead	0.316 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:24	1/4/17 16:57
P16-7048-40	WC#79A	Lead	0.0485 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:27	1/4/17 16:54
P16-7048-41	WC#80A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:28	1/4/17 14:44
P16-7048-42	B#81A	Lead	0.264 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:30	1/4/17 14:49
P16-7048-43	B#82A	Lead	0.695 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:33	1/4/17 14:53
P16-7048-44	B#83A	Lead	0.695 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:34	1/4/17 14:57
P16-7048-45	B#84A	Lead	0.480 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:39	1/4/17 15:01
P16-7048-46	B#85A	Lead	2.85	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:42	1/4/17 15:22
P16-7048-47	B#87A	Lead	3.07	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:45	1/4/17 15:39

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- B = Compound found in blank and samples
- E = Concentration exceeds calibration range
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director

**CERTIFICATE OF ANALYSIS**

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : North Brunswick BOE #6526
PAS Project ID : P16-7048

Matrix : Drinking Water
Report Date : 01/09/17

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P16-7048-48	S#88A	Lead	0.0485 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:48	1/4/17 15:44
P16-7048-49	S#91A	Lead	2.20	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:48	1/4/17 15:48
P16-7048-50	B#93A	Lead	14.7	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:52	1/4/17 16:40
P16-7048-51	B#103A	Lead	6.09	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:56	1/4/17 16:26
P16-7048-52	B#104A	Lead	4.58	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 03:58	1/4/17 16:31
P16-7048-53	NBLP-12-22-FBA	Lead	0.0485 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	12/22/16 04:40	1/4/17 16:35

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
B = Compound found in blank and samples
E = Concentration exceeds calibration range
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director